


Pairing Procedure of Wall Thermostat and Rad Therm with Cube				
Time	Cube		Wall Stat	Rad Therm
28.983		◆	PAIR_PING	
		◆	PAIR_PONG	
29.07		◆	ACK	
29.503		◆	WAKEUP	
		◆	ACK	
29.868		◆	TIME_INFO	
		◆	ACK	
			*** USER PROMPT ***	
01:01.2		◆	SET_GROUPID	
		◆	ACK	
01:01.3	CONFIG_TEMPERATURES	◆		
		◆	ACK	
01:01.4	CONFIG_WEEK_PROFILE	◆		
		◆	ACK	
	CONFIG_WEEK_PROFILE	◆		
		◆	ACK	
	CONFIG_WEEK_PROFILE	◆		
		◆	ACK	
	CONFIG_WEEK_PROFILE	◆		
		◆	ACK	
	CONFIG_WEEK_PROFILE	◆		
		◆	ACK	
	CONFIG_WEEK_PROFILE	◆		
		◆	ACK	
01:03.2	CONFIG_TEMPERATURES	◆		
		◆	ACK	
01:32.0		◆	WAKEUP	
		◆	ACK	
01:33.1		◆		PAIR_PING
		◆	PAIR_PONG	
		◆		ACK
01:33.7		◆	WAKEUP	
		◆		ACK
01:34.0		◆	TIME_INFO	
		◆		ACK
			*** USER PROMPT ***	
01:46.6		◆	WAKEUP	
		◆	ACK	
01:47.0	ADD_LINK_PARTNER	◆		
		◆	ACK	
01:47.3	ADD_LINK_PARTNER	◆		
		◆		ACK
	SET_GROUP_ID	◆		
		◆		ACK
01:47.9	CONFIG_TEMPERATURES	◆		
		◆		ACK
01:48.1	CONFIG_TEMPERATURES	◆		
01:51.2	CONFIG_TEMPERATURES	◆		
		◆		ACK
02:36.1		◆	WAKEUP	
		◆	ACK	
			WALL_THERMOSTAT_CONTROL	
				◆



Cube Set Temperature Messaging				
Time	Cube	Wall Stat		Rad Therm
14:31.8	SET_TEMPERATURE Flag = 0x5 Group ID = 1			
				ACK
14:31.9	SET_TEMPERATURE Flag = 0x5 Group ID = 1			
		ACK		
14:47.9		WALL_THERMOSTAT_CONTROL		
				ACK

Cube Window Sensor Pairing into a room with a wall stat and a radiator thermostat

Time	Cube	Window Sensor	Wall Stat	Rad Therm
19:36.1	PAIR_PING			
	PAIR_PONG			
	ACK			
19:36.6	WAKEUP			
	ACK			
20:29.4	WAKEUP			
	ACK			
20:29.6	ADD_LINK_PARTNER			
	ACK			
	ADD_LINK_PARTNER			
	ACK			
	ADD_LINK_PARTNER			
	ACK			
	ADD_LINK_PARTNER			
	ACK			
20:39.1	WAKEUP			
	ACK			
20:41.2			WALL_THERMOSTAT_CONTROL	
			ACK	